


Jamson Labs

Quality Chemicals Since 1973

Directions:
- As a preventative maintenance measure:

Drip product in the influent at the rate of ¼ to 1-1/2 ppm. (45 drops per minute equals one gallon in 24 hours). A simple water gate valve will maintain drip once set, as low as one pint per day. Drip directly into wet wells and lift stations. Add directly to sewer lines and force mains to remove grease build up.

- Eliminates grease or scum cakes in digester:

Introduce through top digester in any port or inspection holes; 20 to 25 gallons is a good average guideline to follow. After introducing add 500 to 2000 gallons of water, continue to wet down top of grease cake daily. After treating digester, add 1 to 2 gallons daily in sludge compartments. In doing this you are working on the grease cake from top to bottom. After adding through sludge compartment continue circulation as usual.

Orange

95

**FREES HUNG UP OR STUCK FLOATING DIGESTION COVERS BY
MERELY APPLYING AROUND OUTER PERIMETER OF COVER
AND IMMEDIATELY WETTING WITH ORDINARY GARDEN HOSE**

 1 Gal.

 5 Gal.

 55 Gal.

 275 Gal.

Inhalation: None Expected. Remove affected person to fresh air; if symptoms persist seek medical attention.

Skin: None Expected. Remove contaminated clothing; wash affected area with soap and water; launder contaminated clothing before reuse; if irritation persists, seek medical attention.

Eyes: Check for and remove contact lenses. Flush eyes with clear running water for 15 minutes while holding eyelids open; if irritation persists, seek medical attention.

Ingestion: Give two glasses of water for dilution; DO NOT induce vomiting; never give anything by mouth to an unconscious person; seek medical attention.

TRANSPORT INFORMATION:

Proper Shipping Name - Not Regulated for Transport by Truck
DOT Hazard Class - Not Regulated
Packing Group - Not Regulated
ID# - None


Jamson Labs

Quality Chemicals Since 1973

Jamson Laboratories Inc.

(813) 855-4565

FAX (813) 854-3133

In Case Of Chemical Emergency Contact
Chem-Tel 24 Hours (800) 255-3924

**KEEP OUT OF REACH OF CHILDREN.
DO NOT TAKE INTERNALLY.
AVOID CONTACT WITH EYES.**